

CERTIFICATE OF CONFORMITY



1. **HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS**
2. **Certificate No:** FM20CA0019X
3. **Equipment:** Rotex Smart Positioner POSIDAPT Series
(Type Reference and Name)
4. **Name of Listing Company:** Rotex Manufacturers and Engineers Private Limited
5. **Address of Listing Company:** R852/853, TTC Industrial Area, MIDC Rabale, Navi Mumbai
400 701, INDIA
6. The examination and test results are recorded in confidential report number:

PR450998 dated 24th November 2021
7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:

CSA-C22.2 No. 0.4:R2013, CSA-C22.2 No. 0.5:2016, CSA-C22.2 No. 213:2017,
CAN/CSA-C22.2 No. 60079-0:2015, CAN/CSA-C22.2 No. 60079-11:2014, CAN/CSA-C22.2 No. 60079-15:2016, CAN/CSA-C22.2 No. 60529:2016, CAN/CSA-C22.2 No. 61010-1-12:R2017
8. If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.

Certificate issued by:

J.E. Marquedant
VP, Manager - Electrical Systems

24 November 2021

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com



SCHEDULE



Canadian Certificate Of Conformity No: FM20CA0019X

9. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.

10. **Equipment Ratings:**

Intrinsically safe for Class I, Division 1, Groups A, B, C and D; and Class I, Zone 0, Ex ia IIC T5/T6, Non-Incendive for Class I, Division 2, Groups A, B, C and D; and Class I, Zone 2, Ex nA IIC T5/T6 hazardous locations, indoors and outdoors (IP66) with an ambient temperature rating of -25°C to +78°C.

11. **The marking of the equipment shall include:**

Class I Division 1, Groups A, B, C, D; T* Ta = -25°C to +78°C; IP66

Class I, Zone 0, Ex ia IIC; T* Ta = -25°C to +78°C; IP66

Class I, Division 2, Groups A, B, C and D; T* Ta = -25°C to +78°C; IP66

Class I, Zone 2, Ex nA IIC; T* Ta = -25°C to +78°C; IP66

T*: T5 at -25°C to +78°C; T6 at -25°C to +60°C

12. **Description of Equipment:**

The Rotex Smart Positioner POSIDAPT Series is an electronically configurable loop powered device, Digital Positioner operating range of 4-20 mA or 0-20 mA (with External 24 Vdc) and various communication protocol such as HART, Foundation Fieldbus. The Positioner enclosure is constructed from Aluminum alloy or Stainless steel and with Polycarbonate (Makrolon®) or Aluminum alloy or Stainless steel cover. The enclosure is in two halves & held together by 4 stainless steel fasteners.

Operation Temperature Ranges:

The ambient operating temperature range of the Rotex Smart Positioner POSIDAPT Series is -25°C to 78°C.

RTXabcdefghijk, Smart Valve Positioner

a = Model: 5, 6, 7, 8 or 9

b = Enclosure: 5, 6 or 7

c = Servo: 1, 2, 3, 4

d = Port Connection: 2G or 2R

e = Communication: * or H

f = Module: *, P, A or B

g = Cable Entry: 4R or 3M

h = -25°C to +78°C

i = Certification: A

j = Remote Mount: *, RM03, RM04, RM07, RM10, RM20, RM30 or RM45

k = Accessories: *, RC001, PS100, PS200, PL100, or PL200

13. **Specific Conditions of Use:**

1. Potential electrostatic charging hazard. Clean only with a damp cloth.

2. When used within a Zone 0 location, cast-aluminum enclosures shall be installed in such manner as to prevent the possibility of sparks resulting from friction or impact against the enclosure.

3. The positioner is for installation in locations providing protection against the entry of moisture or dust.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com

SCHEDULE



Canadian Certificate Of Conformity No: FM20CA0019X

14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals Canadian Certification Scheme.

15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

16. Certificate History

Details of the supplements to this certificate are described below:

Date	Description
24 th November 2021	Original Issue.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com